

# TRUESDAIL LABORATORIES, INC.

3337 MICHELSON DRIVE, SUITE CN 750, IRVINE, CA 92612

## **Certified Product Listing**

#### For:

Drinking Water System Components - Health Effects

#### Company:

Picote Solutions, Inc. 20810 SE 18th Place Sammamish, WA 98075, United States

#### **Plant Location:**

SO Salt Lake, UT, United States

#### **Standards:**

NSF/ANSI 61 Section 5 - 2016

#### **Certificate:**

Issued: 03/29/2017 Expires: 12/31/2022

#### **Material/Product:**

Coatings

#### **Contact Temperature:**

23 ± 2°C

#### Models:

DC1000E







### **Material Characteristics:**

Minimum pipe diameter (inches): 4

Maximum pipe surface area/volume ratio (sq in/L): 61

Minimum tank size (gallons): 50

Maximum tank surface area/volume ratio (sq in/L): 16.8

Maximum dry film thickness per coat (mils): 125

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 4 days @ 70°F

Shortest cure time between coats or layers: 2 hours

Final cure time: 4 days @ 70°F

Mix ratio: 2:1

Colors: White

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

#### Additional comments:

Flushing or preparation instruction prior to use:

a) Flushing Time: General Flush at 15 minutes

b) Temperature of Flush: 23 ± 2 °C





